

**FAKULTAS KESEHATAN MASYARAKAT  
UNIVERSITAS ANDALAS**

**Skripsi, 22 Juni 2016**

**MELDA NOVITA BURMI, No.BP. 1210331007**

**ANALISIS PENERAPAN ALAT PEMADAM API RINGAN (APAR) DI RSUD  
PADANG PANJANG TAHUN 2016**

xii + 70 halaman, 15 tabel, 4 gambar, 9 Lampiran

**ABSTRAK**

**Tujuan**

APAR adalah alat pemadam api berbentuk tabung yang mudah dilayani oleh satu orang untuk mengendalikan api pada saat awal kebakaran. RSUD Padang Panjang pernah mengalami kebakaran kecil dan saat APAR digunakan, APAR tidak dapat berfungsi. Penelitian ini bertujuan untuk menganalisis penerapan Alat Pemadam Api Ringan (APAR) di RSUD Padang Panjang tahun 2016.

**Metode**

Desain penelitian ini adalah penelitian kualitatif. Penelitian ini dilaksanakan pada bulan Maret sampai Juni 2016 di RSUD Padang Panjang. Teknik penentuan informan dengan *purposive sampling*. Pengumpulan data dengan mengumpulkan data primer dan data sekunder. Pengolahan data dengan cara mereduksi data, penyajian data, penarikan kesimpulan, dan analisa data dilakukan dengan triangulasi sumber dan metode.

**Hasil**

Berdasarkan dari hasil penelitian didapatkan informasi bahwa sosialisasi kebijakan APAR masih kurang, dana khusus untuk penerapan APAR belum ada, dan terbatasnya tenaga profesional untuk menggunakan APAR. Untuk proses, penempatan APAR masih belum maksimal, belum semua pegawai mampu menggunakan APAR sesuai SOP, pemeliharaan APAR juga masih kurang, masih ditemukan APAR yang cacat, tidak adanya pengawas yang ditunjuk khusus untuk APAR. *Outputnya* adalah belum terlaksana penerapan APAR dengan baik di RSUD Padang Panjang.

**Kesimpulan**

Penerapan Alat Pemadam Api Ringan (APAR) di RSUD Padang Panjang belum terlaksana dengan baik, diperlukan komitmen rumah sakit dalam menerapkan APAR sesuai aturan pemerintah, pemeliharaan dan pemantauan yang baik untuk kelancaran penerapan APAR di RSUD Padang Panjang.

**Daftar pustaka** : 27 (1980-2015)

**Kata kunci** : APAR, pegawai, rumah sakit

**FACULTY OF PUBLIC HEALTH  
UNIVERSITY ANDALAS**

**Skripsi, 22 June 2016**

**MELDA NOVITA BURMI, No.BP. 1210331007**

**ANALYSIS OF APPLICATION FIRE EXTINGUISHER IN RSUD PADANG  
PANJANG 2016**

xii + 70 pages, 15 tables, 4 images, 9 Attachment

**ABSTRACT**

**Objective**

APAR is a tube-shaped fire extinguishers are easily serviced by one person to control the fire at the beginning of fire. Hospital Padang Panjang ever experienced small fires and when fire extinguisher used, fire extinguisher can not function well. This study aims to determine the application of fire extinguisher in RSUD Padang Panjang 2016.

**Method**

The design of this research is qualitative research. This research take place on March until June 2016 in RSUD Padang Panjang 2016. Determination technique Informant use purposive sampling. Collecting data with indepth interviews, document review, and observations. Data processing by reducing the data, presentation of data, drawing conclusions, and data analysis by triangulation of sources and methods.

**Results**

Based on the results of research, author get the information that fire extinguisher policy dissemination is still lacking, a special fund for the implementation of fire extinguisher yet, and lack of professional personnel to use the fire extinguisher. Fire extinguisher placement is still not maximal, not all employees were able to use a fire extinguisher according to SOP, fire extinguisher maintenance is also lacking, they discovered the defect fire extinguisher, there is no supervisors that are specific to fire extinguisher. The output is implemented the application of fire extinguisher well in hospitals Padang Panjang not yet.

**Conclusion**

Application of fire extinguisher (APAR) in RSUD Padang Panjang have been running well, needed hospitals in the commitment required by the rules apply fire extinguisher government, maintenance and monitoring both for the smooth implementation of fire extinguisher in hospitals Padang Panjang.

**References** : 27 (1980-2015)

**Key Word** : Fire Extinguisher, hospital, worker