



UNIVERSITAS ANDALAS

**ANALISIS PENERAPAN ALAT PEMADAM API RINGAN (APAR) DI RUMAH
SAKIT UMUM DAERAH DR. RASIDIN PADANG TAHUN 2017**



Oleh :

**NOVA LUCYANA
NO. BP. 1311211002**

Pembimbing I : Luthfil Hadi Anshari, SKM, M.Sc

Pembimbing II : Septia Pristi Rahmah, SKM, MKM

FAKULTAS KESEHATAN MASYARAKAT

UNIVERSITAS ANDALAS

PADANG, 2017

**FAKULTAS KESEHATAN MASYARAKAT
UNIVERSITAS ANDALAS**

Skripsi, April 2017

NOVA LUCYANA, NO. BP. 1311211002

**ANALISIS PENERAPAN ALAT PEMADAM API RINGAN (APAR) DI
RUMAH SAKIT UMUM DAERAH DR. RASIDIN PADANG TAHUN 2017**

xii + 86 halaman, 15 tabel, 6 gambar, 8 lampiran

ABSTRAK

Tujuan Penelitian

Rumah Sakit merupakan institusi pelayanan kesehatan yang berisiko terhadap kebakaran. Pencegahan kebakaran di RS dapat dilakukan dengan menggunakan alat proteksi kebakaran salah satunya APAR. Penelitian ini bertujuan untuk menganalisis penerapan Alat Pemadam Api Ringan (APAR) di RSUD dr. Rasidin Padang.

Metode

Desain penelitian ini adalah penelitian kualitatif. Penelitian ini dilaksanakan pada bulan Desember sampai Maret 2017 di RSUD dr. Rasidin Padang. Teknik penentuan informan dengan *purposive sampling*. Pengumpulan data secara primer dan sekunder. Pengolahan data dengan cara reduksi, penyajian, penarikan kesimpulan, analisa data dilakukan dengan triangulasi sumber dan metode.

Hasil

Secara Input : Kebijakan mengenai penerapan alat pemadam api ringan di RSUD dr. Rasidin belum ada, kurangnya tenaga pengelola APAR, sudah ada dana khusus pengisian APAR dari APBD, tidak ada tanda pemasangan APAR dan SOP penggunaan APAR. Pada prosesnya penempatan APAR telah sesuai dengan potensi bahaya, tidak ada pelatihan pegawai untuk penggunaan APAR, pemeliharaan APAR dilakukan oleh DAMKAR kota Padang dan diawasi oleh bagian IPSRS. Sehingga dapat disimpulkan outputnya bahwa penerapan APAR di RSUD dr. Rasidin belum baik

Kesimpulan

Penerapan APAR di RSUD dr. Rasidin Padang belum terlaksana dengan baik, masih banyak sarana yang kurang diperlukan kebijakan rumah sakit dalam menerapkan APAR sesuai aturan pemerintah, banyak pegawai yang tidak pandai menggunakan APAR. Diharapkan rumah sakit dapat melakukan pelatihan penggunaan APAR, meningkatkan koordinasi dalam pemeliharaan APAR di RSUD dr. Rasidin Padang.

Daftar Pustaka : 40 (1970-2016)

Kata Kunci : Kebakaran, Rumah Sakit, APAR

**FACULTY OF PUBLIC HEALTH
ANDALAS UNIVERSITY**

**Undergraduated Thesis, April 2017
NOVA LUCYANA, NO. BP. 1311211002**

**ANALYSIS OF APPLICATION OF FIRE EXTINGUISHER (FIREX) IN THE
REGIONAL GENERAL HOSPITAL DR.RASIDIN PADANG 2017**

xii + 86 pages, 15 tables, 6 picture, 8 attachements

ABSTRACT

Objective

Hospital is a health care institution which has risk of fire. Fire prevention in hospital can be supported by using fire prevention tools such as FIREX. This study aimed to analyze the application of Fire Extinguisher (FIREX) in RSUD dr. Rasidin Padang.

Method

This research was using a qualitative method. It was conducted in December 2016 until March 2017 in RSUD dr.Rasidin Padang. Informant determination technique used was purposive sampling. The data was collected primerly and secunderly. It was processed by reducing, presentation, drawing conclusions, and data analysis by triangulation of sources and methods.

Result

The result of this research are, input components: Policy on the application of a fire extinguisher in RSUD dr. Rasidin was not applied yet, lack of FIREX management, the existing special funds from the budget for FIREX charging, no sign of FIREX mounting and FIREX usage SOP. For the components process, FIREX placement was appropriate for potential hazards, no employees trained how to use FIREX, maintenance was carried out by the Fire Fighter Team of Padang, and supervision by IPS section. Output component: FIREX application was not in a good implementation yet.

Conclusion

Application of fire extinguisher (FIREX) in RSUD dr.Rasidin was not applied well yet, there were many room for improvement in the hospital policy in applying the FIREX according to government rules, many employees were not able to use a fire extinguisher. It is expected to the hospital to conduct training about using portable fire extinguisher , improve coordination in the maintenance of portable fire extinguisher in RSUD dr.Rasidin Padang.

Bibliography : 40 (1970-2016)

Keywords : Fire, Hospital, FIREX