



UNIVERSITAS ANDALAS

**ANALISIS PELAKSANAAN *PRE FIRE PLANNING* SEBAGAI BENTUK
PENANGGULANGAN BAHAYA KEBAKARAN**

DI PT PERTAMINA (PERSERO)

REFINERY UNIT II DUMAI

TAHUN 2018

Oleh :

REZA KURNIAWAN

No. BP. 1411212051

Pembimbing 1 : Luthfil Hadi Anshari, SKM, M.Sc

Pembimbing 2 : Drs. Zudarmi, M.Si

PROGRAM STUDI ILMU KESEHATAN MASYARAKAT

FAKULTAS KESEHATAN MASYARAKAT

UNIVERSITAS ANDALAS

PADANG, 2018

ABSTRAK

Perusahaan wajib melaksanakan pengendalian setiap perwujudan energi, pengadaan sarana proteksi kebakaran dan sarana penyelamatan jiwa, pembentukan organisasi tanggap darurat serta latihan penanggulangan kebakaran di tempat kerja secara berkala. *Pre Fire Planning* sebagai lathan penanggulangan kebakaran di PT Pertamina (Persero) RU II Dumai telah terlaksana 9 kali dari 12 kali target minimal (dalam persen=75 %). Penelitian ini bertujuan untuk menganalisis pelaksanaan *Pre Fire Planning* sebagai bentuk penanggulangan kebakaran di PT Pertamina (Persero) *Refinery Unit* II Dumai Tahun 2018. Penelitian ini adalah penelitian kualitatif. Penelitian ini dilaksanakan pada bulan Juni hingga sampai September 2018. Teknik penentuan informan dengan *purposive sampling*. Pengumpulan data dilakukan dengan wawancara mendalam, observasi dan telaah dokumen. Pengolahan data dengan mereduksi data, penyajian data, penarikan kesimpulan, dan analisa data dilakukan dengan triangulasi sumber dan metode. Berdasarkan dari hasil penelitian didapatkan informasi bahwa pada komponen input yang berkaitan dengan tenaga ditemukan kekurangan tenaga petugas kebakaran sesuai dengan kebijakan Kepmenakertrans RI No: KEP./186/MEN/1999. Pada komponen proses yang berkaitan dengan pelaksanaan *Pre Fire Planning*, didapatkan info bahwa realisasi pelaksanaan *Pre Fire Planning* hanya terlaksana 9 kali dari 12 kali target pelaksanaannya. *Output*-nya adalah Telah tercapainya kesiapsiagaan kebakaran yang optimal melalui pelaksanaan *Pre Fire Planning* yang baik dan terencana di PT Pertamina (Persero) *Refinery Unit* II Dumai sesuai dengan peraturan-peraturan terkait. Pelaksanaan *Pre Fire Planning* di PT Pertamina (Persero) *Refinery Unit* II Dumai sudah baik, namun masih ditemukan kekurangan dalam jumlah tenaga petugas kebakaran. Disarankan kepada PT Pertamina (Persero) RU II Dumai untuk melakukan penambahan petugas pemadam kebakaran sebanyak 27 orang lagi.

Kata kunci : Pre Fire Planning, Kebakaran, Pertamina.

ABSTRACT

The company is obliged to carry out control of every energy manifestation, provision of fire protection facilities and means of saving lives, establishment of emergency response organizations and fire prevention training in the workplace periodically. Pre Fire Planning as a fire prevention course at PT Pertamina (Persero) RU II Dumai has been implemented 9 times out of 12 minimum targets (in percent = 75%). This study aims to analyze the implementation of Pre Fire Planning as a form of fire prevention at PT Pertamina (Persero) Refinery Unit II Dumai in 2018. This research is qualitative research. This research was conducted in June to September 2018. The technique of determining the informants with purposive sampling. Data collection is done by in-depth interviews, observation and document review. Data processing by reducing data, presenting data, drawing conclusions, and analyzing data is done by triangulating sources and methods. Based on the results of the study, it was obtained information that the energy-related input component found a shortage of fire staff in accordance with the Minister of Manpower and Transmigration's policy No: KEP./186/MEN/1999. In the process component related to the implementation of Pre Fire Planning, obtained information that the realization of the Pre Fire Planning implementation is only done 9 times out of 12 times the target of its implementation. The output is optimal fire preparedness through the implementation of good and planned Pre Fire Planning at PT Pertamina (Persero) RU II Dumai in accordance with relevant regulations. The implementation of Pre Fire Planning at PT Pertamina (Persero) Refinery Unit II Dumai has been good, but there are still deficiencies in the number of fire personnel. It was suggested to PT Pertamina (Persero) RU II Dumai to add 27 firefighters.

Key Words : Pre Fire Planning, Fire, Pertamina.

